

13.04.090 – Sanitary Protection.

- A. On installations which operate with the use of water directly from the public supply system, every direct connection shall be equipped with a suitable brass-body, brass fitted check valve.
- B. Discharge connections for the disposal of wastewaters shall be in strict accordance with regulations.
- C. Cooling waters which are to be reused for other purposes shall be provided with free, above the rim discharge, before entering other equipment; otherwise, permission shall be obtained in writing from the building official the proposed connection and use.
- D. On installations other than those described above, there shall be a physical break between the public water supply piping and the piping of the installation, so arranged as to make impossible back siphonage to the public water system.

(Prior code : § 15.404)